

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 03

Dated: दिनांक - 02.01.24

It is certified that an inspection team headed by Er. BRIJ MOHAN SINGH

(Name of Officers with designation) from ASSISTANCE ENGINEER (PHED)

(Name of Department/ Office) inspected the LAKSHYA INTERNATIONAL SCHOOL
MANUAPUL, GURWALIA BETTIAH W. CHAMPARAN(Name & Address of the school) on (date of inspection) and found that the
LAKSHYA INTERNATIONAL SCHOOL (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic
sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

The above is valid for a period of ONE YEAR.

Signature with Seal: Aug 11/24

Name : सहायक अभियंता

Designation : लो० स्वा० अवर इंजिनियर

Name & Address of the Office / Department :

To

.....

.....

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

Zone - Muzaffarpur

District Name: West Champaran

Division Name: P.H. Division, Bettiah

Format: I

Sl. No.	Block	Panchyat	Village	Village code	Population	Name of Habitation	Location of Source	Latitude	Longitude	Parameters															Remarks
										pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Total Coll	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
1	CHANPATIYA	GURWALLA	MANUWAPUL			MANUWAPUL	LAKSHYA INTERNATIONAL SCHOOL, MANUWAPUL, GURWALLA BORING			7.8	1	350	210	160	48	9.6	20	150	0.10	BDL	25	NT	NT	NEGATIVE	
Desirable Limit (mg/l)										6.5-8.5	1.0	-	500	200	75	30	250	200	1.0	45	200	1.00	0.01	-	-
Permissible Limit* in absence of alternate source(mg/l)										NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.50	NR	**	-

Analyzed water sample conform to indian standard under permissible limit for drinking purpus

Sample Collected by --SUNIL KUMAR JHA, LAKSHYA INTERNATIONAL SCHOOL, MANUWAPUL (BETTIAH)

Vijay Kumar
 Chemist 02/01/2024
 P.H. Division, Bettiah

[Signature]
 Assistant Engineer
 P.H. Sub division, Narhatyaganaj

[Signature]
 Executive Engineer
 P.H. Division, Bettiah

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

No.425.....

Date: 19/12/2022

It is certified that an inspection team by Er. SHRI NIWAS SINGH
ASSISTANT ENGINEER (PHED) (Name of Officers with
designation) from P.H. SUB DIVISION NARKATIAGANJ ^{WEST CHAMPARAN} (Name of
Department/Office) inspected the LAKSHYA INTERNATIONAL SCHOOL
MANUAPUL, GURWALIA, BETTIAH, WEST CHAMPARAN (Name & Address of
the school) on and found that the LAKSHYA INTERNATIONAL
SCHOOL, MANUAPUL, GURWALIA, BETTIAH, WEST CHAMPARAN (Name of school) has
safe drinking water facilities for the students and memories of staff of the
institution and is maintaining the hygienic by the Central/State/U.T Gov.

The above valid for a period of ...ONE YEAR.....

Signature with Seal:

Name

Er. SHRI NIWAS SINGH

Designation

.....

To

LAKSHYA INTERNATIONAL
SCHOOL, MANUAPUL, GURWALIA
BETTIAH, WEST CHAMPARAN

(Name & Address of the Institution)

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

Format: I

Division Name: P.H. Division, Bettiah

Zone - Muzaffarpur District Name: West Champaran				Parameters																			Remarks															
Sl. No.	Block	Panchayat	Village	Village code	Population	Name of Habitation	Location of Source	Latitude	Longitude	pH	Turb	EC	TDS	TH	Ca	Mg	Cl ⁻ Alka.	Fe	NO ₃	SO ₄	F	As	Total Coli	Remarks														
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26													
1	Chanpatiya	Gurwalia	Manuwapul			Manuwapul	Lakshya International School Manuwapul Gurwalia Hand Pump			7.5	2	402	261	200	40	24	20	210	NT	NT	NT	NT	NT	NOT TESTED														
2	Chanpatiya	Gurwalia	Manuwapul			Manuwapul	Lakshya International School Manuwapul Gurwalia Boring			7.7	1	412	258	200	56	14.4	20	220	NT	NT	NT	NT	NT	NOT TESTED														
								Desirable Limit (mg/l)																														
								6.5-8.5																1.0	-	500	200	75	30	250	200	1.0	45	200	1.00	0.01		
								Permissible Limit* in absence of alternate source (mg/l)																NR	50	-	2000	600	200	100	1000	600	NR	NR	400	1.50	NR	**

Analyzed water sample conform to indian standard under permissible limit for drinking purpus

Sample Collected by - Sunil Kumar Jha

Sunil Kumar Jha
Lab Assistant
P.H. Division Bettiah

Vijay Kumar
Chemist
P.H. Division, Bettiah

19.12.22
Assistant Engineer
P.H. Sub. Division, Narkatyaganj

19.12.22
Executive Engineer,
P.H. Division, Bettiah